

Electrical Isolate Lockout Test And Tag Risk Assessment

Business Name:		ABN:
Business Address:		
Contact Person:	Phone:	Email:

THIS RISK ASSESSMENT IS APPROVED BY THE PCBU ON THIS PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a RISK ASSESSMENT is prepared before the proposed work starts.

Full Name:		
Signature:	Title:	Date:

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

Client:	SCOPE OF WORKS
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Date Risk Assessment supplied to Project Manager:	

RISK MATRIX									
LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HIERARCHY OF CONTROLS	
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			Elimination Remove the hazard.	
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	Substitution Replace the hazard.	
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	Isolation Isolate People from the hazard	
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	Engineering Isolate the hazard	
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records.	Administrative Change	
								PPE	
Risk Rating & Required Action:								Notes on Hierarchy of Controls:	
4A Stop work. The risk is intolerable. Eliminate the hazard or redesign the activity before proceeding. A Safe Work Method Statement (SWMS) or higher-level authorisation is required.								Remember to apply controls in the preferred order shown by the coloured pyramid:	
3H Review and approve additional controls before task starts. Senior supervisor sign-off needed.								1. Eliminate	
2M Ensure all nominated controls are in place and effective. Proceed with caution; monitor conditions.								2. Substitute	
1L Proceed, following standard operating procedures. Monitor and keep records.								3. Isolate	
								4. Engineering	
								5. Administrative	
								6. PPE	
Consequence Scale:								Always document why a lower-order control is accepted if elimination or substitution is not reasonably practicable.	
Consequence	People (injury/illness)		Project / Assets		Compliance / Reputation				
Catastrophic	Fatality or permanent total disability		project shutdown		Significant regulator intervention; criminal prosecution				
Major	Serious injury/illness (hospital > 5 days)		critical delay		Improvement notice; major media coverage				
Moderate	Medical-treatment injury; lost-time > 1 day		moderate delay		Minor breach; adverse client comment				
Minor	First-aid only, no lost time		negligible delay		Isolated non-conformance				
Insignificant	No injury		no schedule impact		Deviation caught and corrected on site				
								<i>aligned with Safe Work Australia's Managing the risk of fatigue at work (2023) and ISO 45001:2018 clauses 6–8.</i>	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
1. Preparation	Electric shock, Slip and trip hazards	3H	<ul style="list-style-type: none"> - Conduct a site inspection prior to starting working - Ensure all personnel have completed electrical isolation training - Inspect the area for any slip or trip hazards and address appropriately - Ensure PPE such as insulated gloves and boots are available and worn - Brief all personnel on potential electrical hazards and emergency procedures - Identify and mark the location of control panels and circuit breakers - Verify isolation points are accessible and operational - Double-check that all required tools and equipment are serviceable - Establish a clear communication protocol among team members - Review with safety analysis for all involved tasks 	2M
2. Verification of Tools and Equipment	Tool malfunction, Improper use	3L	<ul style="list-style-type: none"> - Verify calibration and integrity of voltage testers and other equipment - Check that all tools are rated for use on the intended voltage level - Ensure team members are trained in the correct use of tools and equipment - Conduct visual inspections for wear and tear on all tools - Ensure tools are within validity dates, if applicable - Have a qualified electrician supervise the tool testing process - Secure tools using insulated holders to prevent accidental contact - Remove all non-essential tools from the work area to avoid confusion - Clearly label and organise tools for each stage of the process - Prepare a tool checklist and verify against the inventory 	1L
3. Isolation of Electrical Supply	Unexpected energisation, Arc flash	4A	<ul style="list-style-type: none"> - Identify all energy sources that need isolation - Use lockout/tagout devices on all identified sources - Test for the absence of voltage before performing work - Display warning signage around the isolation area - Assign responsibility for lockout devices to individual team members - Implement a check system to ensure that all relevant locks and tags are applied - Avoid working alone; ensure multiple workers verify isolations - Use arc-rated PPE specific to the potential energy level 	2M

<p>tagging, Failure to</p>	<p>3H</p>	<p>Keep detailed records of every locked tagged product performance</p>
<p>Equipment, Residual</p>	<p>3H</p>	<p>Keep detailed records of every locked tagged product performance</p>

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
7. Work Execution	Unexpected energisation, Equipment malfunction	3H		2M
8. Reinstate Electrical Supply	Unexpected energisation, Equipment failure on re-energisation	3H		1L
9. Post-Work Review	Missed hazards in review, Failure to document	2M		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
10. Equipment and Site Cleanup	Physical injury from tools, Chemical exposure from cleaning materials	2M		1L
11. Documentation and Record Keeping	Loss of critical safety data, Inaccurate data entry	2M		1L
12. Feedback Loop and Continuous Improvement	Stagnant safety processes, Lack of feedback incorporation	2M		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
13. Training and Competency Development	Inadequate training, Lack of skilled personnel	3H		1L
14. Emergency Response Planning	Poorly planned emergency response, Delayed action in crisis	4A		1L
15. Equipment Maintenance	Equipment failure, Excessive wear and tear	3H		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
			<div></div> <div></div> <div></div> <div></div> <div></div> <div></div>	
16. Final Review and Closeout	Overlooked hazards, Incomplete processes	2M	<div></div> <div></div> <div></div> <div></div> <div></div> <div></div> <div></div> <div></div> <div></div> <div></div>	1L

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES IF ANY STATE THAT ARE NOT APPLICABLE

Queensland & Australian Capital Territory

Work Health and Safety Act 2011

Work Health and Safety Regulations 2011

Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>

Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>

Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>

Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

Victoria

Occupational Health and Safety Act 2004

Occupational Health and Safety Regulations 2017

Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>

Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

New South Wales

Work Health and Safety Act 2011

Work Health and Safety Regulations 2017

Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>

Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-codes-of-practice>

Western Australia

Work Health and Safety Act 2020

Work Health and Safety Regulations 2022

Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>

Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

Northern Territory

Work Health and Safety (National Uniform Legislation) Act 2011

Work Health and Safety (National Uniform Legislation) Regulations 2011

Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplace-safety-laws>

Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

Safe Work Australia Links

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>

Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

Model Codes of Practice

- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

South Australia

Work Health and Safety Act 2012 (SA)

Work Health and Safety Regulations 2012 (SA)

Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>

Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

Tasmania

Work Health and Safety Act 2012

Work Health and Safety (Transitional and Consequential Provisions) Act 2012

Work Health and Safety Regulations 2012

Work Health and Safety (Transitional) Regulations 2012

Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>

Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.