

Fall Protection	on Systems Installation Risl	k Assessment	
Business Name:		ABN:	
Business Address:			
Contact Person:	Phone:	Ema*	
	·		
THIS RISK ASSESSI	MENT IS APPROVED BY THE PCE	BU OF V PROJECT	
Under the Work Health and Safety Regulation (WHS Regulation), a pis prepared before the proposed work starts.	person conducting a busine or un	dertaking PCBU required to ensu	re that a RISK ASSESSMENT
Full Name:			
Signature:		ııtle:	Date:
CL	OR PRI. CIT. L. CO. TRACTOR I	DETAILS	
Client:		SCOPE OF	WORKS
Project Name:			
Project Address:			
Project Manager:			
Contact Phone:			
Date Risk Assessment supplied to Project Iv.			

Version 2.5 Authorised by Review # Review Date:



RISK MATRIX LIKELIHOOD INSIGNIFICANT MINOR MODERATE MAJOR CATASTROPHIC HIERARCHY OF CONTROLS SCORE ACTION Elimination ALMOST 3 HIGH 3 HIGH 4 4 ACUTE ACUTE ACUTE **CERTAIN** Remove the hazard. Substitution 4 4 DO NOT Replace the hazard. LIKELY MODERATE HIGH HIGH ACUTE ACUTE ACUTE ROCEED Isolation Isolate People from the hazard 2 3 4 3H Rev before POSSIBLE MODERATE ACUTE ACUTE LOW HIGH HIGH. work Engineering Isolate the l/Acchanich. Ensure control 2 3 2M istrativ UNLIKELY measures in LOW LOW MODERATE HIGH ACU RATE е place. Chang 2 MODERATE 3 HIGH 1L Monitor and RARE LOW LOW LOW keep records.

Risk Rating & Required Action:

4A	Stop work. The risk is intolerable,	minate the hazard	redesign the activity before proceeding. A Safe Work
	Method Statement (SWMS) or hi	er-level authorisation	is required.
3H	Review and approve additional c	role ask	arts. Senior supervisor sign-off needed.
2M	Ensure all nominated controls are in	prace and efficive	Proceed with caution; monitor conditions.
1L	Proceed, following standard operating	ng procedurer //oni	itor and keep records.

Consequence Scale:

Consequence	People (injury/illness)	Project / Assets	Compliance / Reputation
Catastrophic	Fatality or permanent total disability	project shutdown	Significant regulator intervention; criminal prosecution
Major	Serious injury/illness (hospital > 5 days)	critical delay	Improvement notice; major media coverage
Moderate	Medical-treatment injury; lost-time > 1 day	moderate delay	Minor breach; adverse client comment
Minor	First-aid only, no lost time	negligible delay	Isolated non-conformance
Insignificant	No injury	no schedule impact	Deviation caught and corrected on site

Notes on Hierarchy of Controls:

Remember to apply controls in the preferred order shown by the coloured pyramid:

- 1. Eliminate
- Substitute
- 3. Isolate
- 4. Engineering
- 5. Administrative
- 6. PPE

Always document **why** a lower-order control is accepted if elimination or substitution is not reasonably practicable.

aligned with Safe Work Australia's Managing the risk of fatigue at work (2023) and ISO 45001:2018 clauses 6–8.



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
1. Preparation	incorrect planning, lack of equipment inspection	ЗН	- Develop a comprehensive safety plan. - Ensure all equipment is available and account a ror. - Conduct a pre-installation meeting to reviewall procedure. - Verify all workers are trained in fall protection visiture. - Inspect all equipment before use for defects. - Correct any identified equipment defects prior to work. - Assign roles and a spoke lilities at the team. - Prepare all the ety documentation as operm? - Ensure appropriate signing e is availab. - According unique and for all workers.	2M
2. Site Assessment	unsafe work environment uneven surfaces	33	 Condula a through subassessment prior to installation. Contifying poor tial hazards on-site and address them. Gath of the ain information and determine access points. Check for uneven surfaces and secure where possible. Establish controlled access zones. Use site maps to identify restricted areas. Change work zone layouts as necessary. Mark all sliding or sloped areas with signs or barriers. Confirm that working surfaces have the load capacity. Consult with the site manager regarding unusual conditions. 	2M
3. Use of Ladders	ladder instability, improper use	ЗН	 Choose ladders suited to the task and load requirements. Inspect ladders for damage before use. Place ladders on stable, level surfaces. Ensure ladders are set at the correct angle. Use ladders for short duration tasks only. Ladder placement should avoid traffic areas to prevent collisions. Provide ladder safety training to workers. Use non-slip ladder feet or mats when needed. 	1L



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
			- Encourage a three-point contact rule when climbing.	
			- Secure the top of the ladder to a stable structure.	
4. Scaffolding Setup	collapse, fall from height	4A		2M
5. Personal Fall Arrest Systems Use	failure of equipmed lincorp	4A		2M
6. Installing Anchor Points	anchor point failure, incorrect location	ЗН		1L



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
7. Rooftop Safety	edge falls, slippery surfaces	4A		2M
8. Use of Tools	tool malfunction, incorrect tool use	зн		1L
9. Secure Materials	falling objects, material instability	ЗН		1L



6

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
10. Fall Prevention Training	lack of skill, incorrect emergency response	3H		1L
11. Bad Weather Adaptations	reduced visibility, strong	4A		2M
12. Working at Heights Protocols	insufficient barriers, no fall protection	4A		2M



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
13. First Aid Arrangements	delayed response, insufficient provisions	3Н		1L
14. Incident Reporting	underreporting, deception of incidents	ЗН		1L
15. Post-Installation Review	loose components, incomplete systems	ЗН		1L



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAI RISK
	5			



EMERGENCY RESPONSE - CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES. ANY STATE OF AT ARE NOT APPLICABLE.

Queensland & Australian Capital Territory

Work Health and Safety Act 2011

Work Health and Safety Regulations 2011

 $\textbf{Legislation QLD:} \ \underline{\textbf{https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws}$

Codes of Practice QLD: https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice Legislation ACT: https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations

Codes of Practice ACT: https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice

New South Wales

Work Health and Safety Act 2011

Work Health and Safety Regulations 2017

Legislation NSW: https://www.safework.nsw.gov.au/legal-obligations/legislatide

Codes of Practice NSW: https://www.safework.nsw.gov.au/resource-library/lis

Northern Territory

Work Health and Safety (National Uniform Legislation) Act 2011

Work Health and Safety (National Uniform Legislation) Regulation 201

Codes of Practice NT: https://worksafe.nt.gov.au/f

South Australia

Work Health and Safety Act 2012 (SA)

Work Health and Safety Regulations 2012 (SA)

Legislation for SA: https://www.safework.sa.gov.au/resources/le_lation

Codes of Practice for SA: https://www.safework.sa.gov.au/wor aces/codes-of-practice#COPs

Tasmania

Work Health and Safety Act 2012

Work Health and Safety (Transitional and Consequential Provisions) Act 2012

Work Health and Safety Regulations 2012

Work Health and Safety (Transitional) Regulations 2012

Legislation for TAS: https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations

Codes of Practice for TAS: https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.

Victoria

Occupational Health al. Safety Act

Occupational Health and Infety gulations 2017

Legis on VIC: https://www.csafe.vic.gov.au/occupational-health-and-safety-act-and-

gulat

des on actice VI autros://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice

Western Australia

Work Health and Safety Act 2020

Work Health and Safety Regulations 2022

Legislation Western Australia: https://www.commerce.wa.gov.au/worksafe/legislation

Codes of Practice WA: https://www.commerce.wa.gov.au/worksafe/codes-practice

Safe Work Australia Links

Law and Regulation (All States): https://www.safeworkaustralia.gov.au/law-and-regulation Model Codes of Practice: https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice

Model Codes of Practice

- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work