

High-Voltage Switching Risk Assessment

Business Name:	ABN:	
Business Address:		
Contact Person:	Phone:	Email:

THIS RISK ASSESSMENT IS APPROVED BY THE PCBU ON THIS PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a RISK ASSESSMENT is prepared before the proposed work starts.

Full Name:		
Signature:	Title:	Date:

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

Client:	SCOPE OF WORKS
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Date Risk Assessment supplied to Project Manager:	

RISK MATRIX									
LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HIERARCHY OF CONTROLS	
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			Elimination Remove the hazard.	
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	Substitution Replace the hazard.	
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	Isolation Isolate People from the hazard	
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	Engineering Isolate the hazard	
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records.	Administrative Change	
								PPE	
Risk Rating & Required Action:								Notes on Hierarchy of Controls:	
4A Stop work. The risk is intolerable. Eliminate the hazard or redesign the activity before proceeding. A Safe Work Method Statement (SWMS) or higher-level authorisation is required.								Remember to apply controls in the preferred order shown by the coloured pyramid:	
3H Review and approve additional controls before task starts. Senior supervisor sign-off needed.								1. Eliminate	
2M Ensure all nominated controls are in place and effective. Proceed with caution; monitor conditions.								2. Substitute	
1L Proceed, following standard operating procedures. Monitor and keep records.								3. Isolate	
								4. Engineering	
								5. Administrative	
								6. PPE	
Consequence Scale:								Always document why a lower-order control is accepted if elimination or substitution is not reasonably practicable.	
Consequence	People (injury/illness)		Project / Assets		Compliance / Reputation				
Catastrophic	Fatality or permanent total disability		project shutdown		Significant regulator intervention; criminal prosecution				
Major	Serious injury/illness (hospital > 5 days)		critical delay		Improvement notice; major media coverage				
Moderate	Medical-treatment injury; lost-time > 1 day		moderate delay		Minor breach; adverse client comment				
Minor	First-aid only, no lost time		negligible delay		Isolated non-conformance				
Insignificant	No injury		no schedule impact		Deviation caught and corrected on site				
								<i>aligned with Safe Work Australia's Managing the risk of fatigue at work (2023) and ISO 45001:2018 clauses 6–8.</i>	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
1. Preparation	Electric shock, Fire risk	4A	<ul style="list-style-type: none"> - Ensure all personnel are trained in high-voltage safety procedures - Verify that all equipment and tools are rated for high-voltage use - Ensure all personnel are wearing appropriate PPE, including rubber gloves and insulating boots - Conduct a thorough inspection of all equipment to ensure there are no faults - Implement a lockout/tagout (LOTO) system to secure energy sources - Obtain necessary permits for work involving high-voltage equipment - Ensure emergency response procedures are in place and understood - Secure the area to restrict access to authorized personnel only - Confirm weather conditions are suitable for outdoor high-voltage work - Ensure communication devices are functional and reliable 	2M
2. Isolation of Power Source	Accidental energising through	4H	<ul style="list-style-type: none"> - Implement lockout/tagout (LOTO) procedures to physically disconnect power sources - Place clear and visible warning signs around the isolation point - Use insulated tools and equipment for any manual operations - Conduct a double-check verification by a second qualified professional - Confirm the power is completely de-energised using appropriate testing equipment - Maintain a communication line between the team conducting isolation and the operational control centre - Document and log the isolation process in accordance with company policy - Provide barricades around the isolation area - Ensure all personal protective equipment (PPE) is worn at all times - Conduct an isolation brief with all team members 	1L
3. Testing for Absence of Voltage	Surge release, Contact with live parts	3H	<ul style="list-style-type: none"> - Use calibrated and certified testing instruments - Follow manufacturer's protocols for verifying the absence of voltage - Ensure a second certified worker validates the voltage absence test - Use non-contact voltage testers initially, followed by contact testers - Maintain a safe working distance until absence of voltage is confirmed - Continuously monitor environmental conditions for any changes - Record and log test results accurately in work records - Keep a kit containing equipment for emergencies nearby 	2M

Category	Sub-category	Count	Percentage
Human Factors	Operator error	4	4A
	Equipment failure	3	3H

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
7. Restoring Power	Unexpected faults, Arc flash			2M
8. Post-Operation Inspection	Equipment malfunction, Site hazards	3H		1L

Starting, Miscommunication 2M

, System Inefficiencies

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
12. Equipment Maintenance	Wear and tear, Manufacturing defects	3H		2M
13. Emergency Preparedness	Unexpected escalations, Evacuation failures	4A		2M
14. Personal Protective Equipment (PPE) Management	Improper usage, Inadequate PPE supplies	3H		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
15. Communication and Coordination	Misinterpretation of instructions, Delayed response	3H		1L

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES IF ANY STATE THAT ARE NOT APPLICABLE

Queensland & Australian Capital Territory

Work Health and Safety Act 2011

Work Health and Safety Regulations 2011

Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>

Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>

Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>

Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

Victoria

Occupational Health and Safety Act 2004

Occupational Health and Safety Regulations 2017

Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>

Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

New South Wales

Work Health and Safety Act 2011

Work Health and Safety Regulations 2017

Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>

Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-codes-of-practice>

Western Australia

Work Health and Safety Act 2020

Work Health and Safety Regulations 2022

Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>

Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

Northern Territory

Work Health and Safety (National Uniform Legislation) Act 2011

Work Health and Safety (National Uniform Legislation) Regulations 2011

Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplace-safety-laws>

Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

Safe Work Australia Links

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>

Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

Model Codes of Practice

- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

South Australia

Work Health and Safety Act 2012 (SA)

Work Health and Safety Regulations 2012 (SA)

Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>

Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

Tasmania

Work Health and Safety Act 2012

Work Health and Safety (Transitional and Consequential Provisions) Act 2012

Work Health and Safety Regulations 2012

Work Health and Safety (Transitional) Regulations 2012

Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>

Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.