

Installing New Transformers Risk Assessment

| | | |
|-------------------|--------|--------|
| Business Name: | ABN: | |
| Business Address: | | |
| Contact Person: | Phone: | Email: |

THIS RISK ASSESSMENT IS APPROVED BY THE PCBU ON THE PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a RISK ASSESSMENT is prepared before the proposed work starts.

| | | |
|------------|--------|-------|
| Full Name: | | |
| Signature: | Title: | Date: |

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

| | |
|---|----------------|
| Client: | SCOPE OF WORKS |
| Project Name: | |
| Project Address: | |
| Project Manager: | |
| Contact Phone: | |
| Date Risk Assessment supplied to Project Manager: | |

RISK MATRIX

| LIKELIHOOD | INSIGNIFICANT | MINOR | MODERATE | MAJOR | CATASTROPHIC | SCORE | ACTION | HIERARCHY OF CONTROLS |
|----------------|---------------|---------------|---------------|------------|--------------|----------------|-----------------------------------|--|
| ALMOST CERTAIN | 3 HIGH | 3 HIGH | 4 ACUTE | 4 ACUTE | 4 ACUTE | | | Elimination Remove the hazard. |
| LIKELY | 2 MODERATE | 3 HIGH | 3 HIGH | 4 ACUTE | 4 ACUTE | 4A ACUTE | DO NOT PROCEED | Substitution Replace the hazard. |
| POSSIBLE | 1 LOW | 2 MODERATE | 3 HIGH | 4 ACUTE | 4 ACUTE | 3H HIGH | Review before work starts. | Isolation Isolate People from the hazard |
| UNLIKELY | 1 LOW | 1 LOW | 2 MODERATE | 3 HIGH | 4 ACUTE | 2M MODERATE | Ensure control measures in place. | Engineering Isolate the hazard |
| RARE | 1 LOW | 1 LOW | 2 MODERATE | 3 HIGH | 3 HIGH | 1L LOW | Monitor and keep records. | Administrative Change |
| | | | | | | | | PPE |

Risk Rating & Required Action:

| | |
|-----------|---|
| 4A | Stop work. The risk is intolerable. Eliminate the hazard or redesign the activity before proceeding. A Safe Work Method Statement (SWMS) or higher-level authorisation is required. |
| 3H | Review and approve additional controls before task starts. Senior supervisor sign-off needed. |
| 2M | Ensure all nominated controls are in place and effective. Proceed with caution; monitor conditions. |
| 1L | Proceed, following standard operating procedures. Monitor and keep records. |

Consequence Scale:

| Consequence | People (injury/illness) | Project / Assets | Compliance / Reputation |
|----------------------|---|--------------------|--|
| Catastrophic | Fatality or permanent total disability | project shutdown | Significant regulator intervention; criminal prosecution |
| Major | Serious injury/illness (hospital > 5 days) | critical delay | Improvement notice; major media coverage |
| Moderate | Medical-treatment injury; lost-time > 1 day | moderate delay | Minor breach; adverse client comment |
| Minor | First-aid only, no lost time | negligible delay | Isolated non-conformance |
| Insignificant | No injury | no schedule impact | Deviation caught and corrected on site |

Notes on Hierarchy of Controls:

Remember to apply controls in the preferred order shown by the coloured pyramid:

1. **Eliminate**
2. **Substitute**
3. **Isolate**
4. **Engineering**
5. **Administrative**
6. **PPE**

Always document **why** a lower-order control is accepted if elimination or substitution is not reasonably practicable.

aligned with Safe Work Australia's Managing the risk of fatigue at work (2023) and ISO 45001:2018 clauses 6–8.

| JOB STEP | POTENTIAL HAZARDS | IR | CONTROL MEASURES | RR |
|----------------------------|--|--------------|--|---------------|
| SPECIFIC WORK STEPS | HAZARDS THAT MAY ARISE | INITIAL RISK | SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS | RESIDUAL RISK |
| 1. Preparation | Electrical shock, Heavy lifting injuries | 3H | <ul style="list-style-type: none"> - Ensure all personnel are trained in manual handling techniques. - Conduct a toolbox meeting to discuss lifting procedures. - Verify isolation procedures are in place to prevent electrical accidents. - Use adequate personal protective equipment (PPE) like gloves and boots. - Assess weather conditions to avoid work in hazardous environments. - Ensure communication devices are used for team coordination. - Confirm the availability of the emergency response plan. - Use signs and barriers to restrict access to the work area. - Allocate sufficient resources and tools for the task. - Conduct an equipment check prior to the task. | 2M |
| 2. Site Inspection | Trip and fall, Presence of hazardous materials | 3H | <ul style="list-style-type: none"> - Identify and mark all hazards in the work area. - Arrange for the removal of unnecessary debris and materials. - Ensure appropriate signage is displayed to warn of hazards. - Conduct an air quality check for toxic substances. - Utilize appropriate personal protective equipment, such as masks. - Install temporary lighting to improve visibility. - Designate walkways and barriers for navigation. - Train staff on how to recognise hazardous materials. - Provide cleanup kits for oil and chemical spills. - Review hazardous material data sheets for the site. | 1L |
| 3. Delivery of Transformer | Vehicle collision, Improper unloading | 4A | <ul style="list-style-type: none"> - Ensure only trained personnel operate delivery vehicles. - Implement traffic management plans for the delivery route. - Use spotters to guide vehicle movements on site. - Inspect vehicles for any mechanical faults prior to the task. - Ensure all delivery schedules are coordinated to avoid congestion. - Use proper unloading techniques and appropriate equipment. - Maintain communication between drivers and site personnel. - Secure the area to avoid unauthorised access. | 2M |

| JOB STEP | POTENTIAL HAZARDS | IR | CONTROL MEASURES | RR |
|----------------------------|--------------------------------------|--------------|--|---------------|
| SPECIFIC WORK STEPS | HAZARDS THAT MAY ARISE | INITIAL RISK | SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS | RESIDUAL RISK |
| | | | - Provide stabilisers for unloading equipment. - Confirm vehicle locks and restraints are secure before movement. | |
| 4. Rigging and Lifting | Equipment failure, Swinging loads | 4A | | 2M |
| 5. Positioning Transformer | Incorrect alignment, Crushing injury | 3H | | 1L |
| 6. Electrical Connection | Electrical shock, Arc flash | 4A | | 2M |

| JOB STEP | POTENTIAL HAZARDS | IR | CONTROL MEASURES | RR |
|-------------------------------------|--|--------------|--|---------------|
| SPECIFIC WORK STEPS | HAZARDS THAT MAY ARISE | INITIAL RISK | SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS | RESIDUAL RISK |
| | | | | |
| 7. Commissioning Tests | High voltage, Unexpected activation | 4A | | 2M |
| 8. Environmental Hazards Management | Oil spill, Chemical | 3H | | 1L |
| 9. Safety Barrier Installation | Inadequate barriers, Unauthorised access | 3H | | 1L |

| JOB STEP | POTENTIAL HAZARDS | IR | CONTROL MEASURES | RR |
|-------------------------------------|---|--------------|--|---------------|
| SPECIFIC WORK STEPS | HAZARDS THAT MAY ARISE | INITIAL RISK | SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS | RESIDUAL RISK |
| | | | | |
| 10. Final Inspection | Oversight of faults, Verification omissions | 3H | | 1L |
| 11. Employee Training and Induction | Inadequate training, Ignorance of procedures | 2M | | 1L |
| 12. Communication and Coordination | Poor communication, Misunderstanding of tasks | 3H | | 1L |

| JOB STEP | POTENTIAL HAZARDS | IR | CONTROL MEASURES | RR |
|----------------------------------|--|--------------|--|---------------|
| SPECIFIC WORK STEPS | HAZARDS THAT MAY ARISE | INITIAL RISK | SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS | RESIDUAL RISK |
| | | | | |
| 13. Emergency Preparedness | Inadequate emergency plans, Delayed emergency response | 4A | | 2M |
| 14. Post-Installation Monitoring | Structural integrity issues, Functional failures | 3H | | 1L |
| 15. Project Debrief | Inadequate project evaluation, Lack of feedback collection | 2M | | 1L |

| JOB STEP | POTENTIAL HAZARDS | IR | CONTROL MEASURES | RR |
|---------------------|------------------------|--------------|---|---------------|
| SPECIFIC WORK STEPS | HAZARDS THAT MAY ARISE | INITIAL RISK | SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS | RESIDUAL RISK |
| | | | <div></div> <div></div> <div></div> <div></div> <div></div> <div></div> <div></div> | |
| | | | | |

SAMPLE

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES IF ANY STATE THAT ARE NOT APPLICABLE

Queensland & Australian Capital Territory

Work Health and Safety Act 2011

Work Health and Safety Regulations 2011

Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>

Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>

Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>

Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

Victoria

Occupational Health and Safety Act 2004

Occupational Health and Safety Regulations 2017

Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>

Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

New South Wales

Work Health and Safety Act 2011

Work Health and Safety Regulations 2017

Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>

Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-codes-of-practice>

Western Australia

Work Health and Safety Act 2020

Work Health and Safety Regulations 2022

Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>

Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

Northern Territory

Work Health and Safety (National Uniform Legislation) Act 2011

Work Health and Safety (National Uniform Legislation) Regulations 2011

Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplace-safety-laws>

Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

Safe Work Australia Links

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>

Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

Model Codes of Practice

- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

South Australia

Work Health and Safety Act 2012 (SA)

Work Health and Safety Regulations 2012 (SA)

Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>

Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

Tasmania

Work Health and Safety Act 2012

Work Health and Safety (Transitional and Consequential Provisions) Act 2012

Work Health and Safety Regulations 2012

Work Health and Safety (Transitional) Regulations 2012

Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>

Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.