

Inverter Systems Repair Risk Assessment

Business Name:		ABN:
Business Address:		
Contact Person:	Phone:	Email:

THIS RISK ASSESSMENT IS APPROVED BY THE PCBU ON THIS PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a RISK ASSESSMENT is prepared before the proposed work starts.

Full Name:		
Signature:	Title:	Date:

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

Client:	SCOPE OF WORKS
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Date Risk Assessment supplied to Project Manager:	

RISK MATRIX									
LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HIERARCHY OF CONTROLS	
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			Elimination Remove the hazard.	
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	Substitution Replace the hazard.	
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	Isolation Isolate People from the hazard	
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	Engineering Isolate the hazard	
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records.	Administrative Change	
								PPE	
Risk Rating & Required Action:								Notes on Hierarchy of Controls:	
4A		Stop work. The risk is intolerable. Eliminate the hazard or redesign the activity before proceeding. A Safe Work Method Statement (SWMS) or higher-level authorisation is required.						Remember to apply controls in the preferred order shown by the coloured pyramid:	
3H		Review and approve additional controls before task starts. Senior supervisor sign-off needed.						1. Eliminate	
2M		Ensure all nominated controls are in place and effective. Proceed with caution; monitor conditions.						2. Substitute	
1L		Proceed, following standard operating procedures. Monitor and keep records.						3. Isolate	
								4. Engineering	
								5. Administrative	
								6. PPE	
Consequence Scale:								Always document why a lower-order control is accepted if elimination or substitution is not reasonably practicable.	
Consequence	People (injury/illness)		Project / Assets		Compliance / Reputation				
Catastrophic	Fatality or permanent total disability		project shutdown		Significant regulator intervention; criminal prosecution				
Major	Serious injury/illness (hospital > 5 days)		critical delay		Improvement notice; major media coverage				
Moderate	Medical-treatment injury; lost-time > 1 day		moderate delay		Minor breach; adverse client comment				
Minor	First-aid only, no lost time		negligible delay		Isolated non-conformance				
Insignificant	No injury		no schedule impact		Deviation caught and corrected on site				
								<i>aligned with Safe Work Australia's Managing the risk of fatigue at work (2023) and ISO 45001:2018 clauses 6–8.</i>	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
1. Preparation	Inadequate tools, Insufficient knowledge	3H	<ul style="list-style-type: none"> - Ensure all tools are available and serviceable - Conduct a toolbox meeting to discuss the task - Verify the competency of workers - Prepare a checklist for equipment and components - Read and understand inverter system manuals - Confirm availability of safety data sheets - Secure area to prevent unauthorized access - Ensure communication devices are working - Review emergency procedures - Clean the work area to avoid slip hazards 	1L
2. Isolation of Power	Electrical shock, Uncontrolled energy release	4H	<ul style="list-style-type: none"> - Use lockout/tagout procedures - Verify all power sources are disconnected - Wear insulated gloves and PPE - Use insulated tools - Display adequate signage - Confirm all capacitors are discharged - Identify energy sources and label them - Consult electrical schematics - Radio communication with supervisor - Keep emergency contact numbers available 	2M
3. Removal of Inverter Cover	Sharp edges, Falling objects	3H	<ul style="list-style-type: none"> - Wear cut-resistant gloves - Use proper lifting techniques - Inspect work area for stability - Use non-slip footwear - Employ buddy system during removal - Maintain work area cleanliness - Secure tools to avoid dropping - Provide suitable lifting aids 	1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
			- Conduct regular inspections of PPE - Keep first aid kits accessible	
4. Inspection of Inverter Components	Contact with moving parts, Exposure to live circuits	3H	<ul style="list-style-type: none"> Wear safety glasses at all times. De-energize the system before inspection. Use insulated tools. Keep hands dry. Do not touch live components. Warn others of work area. Follow lockout/tagout procedures. Inspect for damaged insulation. Check for loose connections. Avoid leaning against equipment. Use proper lifting techniques. Stay clear of rotating parts. Report any hazards immediately. 	1L
5. Cleaning of Components	Chemical exposure, Eye injuries	3H	<ul style="list-style-type: none"> Read MSDS for cleaning agents. Wear gloves and eye protection. Work in well-ventilated area. Dilute chemicals as instructed. Test for leaks before cleaning. Use soft cloths or brushes. Rinse thoroughly after cleaning. Dispose of waste properly. Label cleaned components. Store cleaning materials safely. Post warning signs. Have spill kit nearby. Never mix different cleaners. Take breaks if working long hours. 	1L
6. Replacement of Faulty Parts	Improper installation, Damage to new parts	4A	<ul style="list-style-type: none"> Identify correct replacement part. Review manufacturer's instructions. Disconnect power before work. Remove old part carefully. Prepare mounting surface. Align new part correctly. Tighten bolts to spec. Double-check wiring connections. Test operation after install. Secure all loose wires. Reconnect power. Monitor for unusual sounds. Document the repair. Inform supervisor of completion. 	2M

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
7. Reassembly of Inverter Cover	Pinch points, Loose fasteners	3H		1L
8. Reconnection of Power	Short circuits, Unexpected activation	4A		2M
9. Testing of System Functionality	Electrical burns, False readings	3H		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
10. De-isolation of System	Residual energy, Interaction with live parts	3H		1L
11. Final Inspection	Overlooked hazards, Insecure connections	3H		1L
12. Restoration of Work Area	Trip hazards, Leftover materials	2M		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
13. Communication of System Status	Miscommunication, Lack of updates	2M		1L
14. Monitoring and Review	Missed faults, Data disclosure	2M		1L
15. Decommissioning Procedures if Required	Occupational exposure, Environmental harm	3H		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
			<div></div> <div></div> <div></div> <div></div> <div></div> <div></div>	

SAMPLE

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES IF ANY STATE THAT ARE NOT APPLICABLE

Queensland & Australian Capital Territory

Work Health and Safety Act 2011

Work Health and Safety Regulations 2011

Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>

Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>

Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>

Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

Victoria

Occupational Health and Safety Act 2004

Occupational Health and Safety Regulations 2017

Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>

Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

New South Wales

Work Health and Safety Act 2011

Work Health and Safety Regulations 2017

Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>

Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-codes-of-practice>

Western Australia

Work Health and Safety Act 2020

Work Health and Safety Regulations 2022

Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>

Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

Northern Territory

Work Health and Safety (National Uniform Legislation) Act 2011

Work Health and Safety (National Uniform Legislation) Regulations 2011

Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplace-safety-laws>

Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

Safe Work Australia Links

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>

Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

Model Codes of Practice

- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

South Australia

Work Health and Safety Act 2012 (SA)

Work Health and Safety Regulations 2012 (SA)

Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>

Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

Tasmania

Work Health and Safety Act 2012

Work Health and Safety (Transitional and Consequential Provisions) Act 2012

Work Health and Safety Regulations 2012

Work Health and Safety (Transitional) Regulations 2012

Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>

Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.