

Working Near Light Fixtures Risk Assessment

Business Name:		ABN:
Business Address:		
Contact Person:	Phone:	Email:

THIS RISK ASSESSMENT IS APPROVED BY THE PCBU ON THIS PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a RISK ASSESSMENT is prepared before the proposed work starts.

Full Name:		
Signature:	Title:	Date:

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

Client:	SCOPE OF WORKS
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Date Risk Assessment supplied to Project Manager:	

RISK MATRIX									
LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HIERARCHY OF CONTROLS	
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			Elimination Remove the hazard.	
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	Substitution Replace the hazard.	
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	Isolation Isolate People from the hazard	
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	Engineering Isolate the hazard	
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records.	Administrative Change	
								PPE	
Risk Rating & Required Action:								Notes on Hierarchy of Controls:	
4A Stop work. The risk is intolerable. Eliminate the hazard or redesign the activity before proceeding. A Safe Work Method Statement (SWMS) or higher-level authorisation is required.								Remember to apply controls in the preferred order shown by the coloured pyramid:	
3H Review and approve additional controls before task starts. Senior supervisor sign-off needed.								1. Eliminate	
2M Ensure all nominated controls are in place and effective. Proceed with caution; monitor conditions.								2. Substitute	
1L Proceed, following standard operating procedures. Monitor and keep records.								3. Isolate	
								4. Engineering	
								5. Administrative	
								6. PPE	
Consequence Scale:								Always document why a lower-order control is accepted if elimination or substitution is not reasonably practicable.	
Consequence	People (injury/illness)		Project / Assets		Compliance / Reputation				
Catastrophic	Fatality or permanent total disability		project shutdown		Significant regulator intervention; criminal prosecution				
Major	Serious injury/illness (hospital > 5 days)		critical delay		Improvement notice; major media coverage				
Moderate	Medical-treatment injury; lost-time > 1 day		moderate delay		Minor breach; adverse client comment				
Minor	First-aid only, no lost time		negligible delay		Isolated non-conformance				
Insignificant	No injury		no schedule impact		Deviation caught and corrected on site				
								aligned with Safe Work Australia's Managing the risk of fatigue at work (2023) and ISO 45001:2018 clauses 6–8.	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
1. Preparation	electrical shock, falling debris	3H	<ul style="list-style-type: none"> - Conduct a toolbox talk to address potential hazards - Ensure all workers are wearing PPE including hard hats and gloves - Verify that tools and equipment are in good working order - Create a safe perimeter around work area with signage and barriers - Designate a safety officer to monitor the activities - Brief workers on emergency procedures - Ensure communication devices are functioning properly - Establish clear and concise hand signals for communication - Inspect the area for any existing damage - Schedule work during off-peak hours when possible 	2M
2. Reviewing blueprints	incorrect data interpretation, lack of lighting leading to mistakes	2M	<ul style="list-style-type: none"> - Use adequate lighting to ensure visibility - Double-check blueprint details with a second team member - Cross-reference with digital plans if available - Train workers on interpreting blueprints - Encourage questions and clarification from workers - Confirm all measurements meet standards - Keep all blueprints updated with latest information - Regularly review work against blueprints - Use visual aids if available to assist understanding - Record any discrepancies for review 	1L
3. Scaffolding setup	falling from height, scaffold collapse	4A	<ul style="list-style-type: none"> - Ensure scaffolding is constructed by trained personnel - Inspect scaffolding for damage or instability before use - Install guard rails and toe-boards on scaffolds - Do not overload scaffolding beyond its capacity limits - Use safety harnesses when necessary - Keep working platforms clear of unnecessary materials - Regularly inspect and maintain scaffolding during use - Only use scaffolding in suitable weather conditions 	2M

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
			- Provide training on safe scaffolding practices - Extend access ladders sufficiently above platforms	
4. Gaining access to fixtures	overhead obstacle collision, instability on ladder	3H	[Redacted Control Measures]	1L
5. Disconnecting power	electric shock, improper lockout/tagout procedure	4A	[Redacted Control Measures]	2M
6. Removing light fixture	falling fixtures, electric shock	3H	[Redacted Control Measures]	1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
7. Inspect and prepare replacement fixture	handling damage, incorrect component usage	3H		1L
8. Installing replacement fixture	fixture instability, incorrect installation leading to hazard	4A		2M
9. Reconnecting power	electric shock, incomplete reinstallation	4A		2M

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
10. Testing new fixture	malfunction triggering fire, overload of electrical system	4A		2M
11. Clean work area	slips from debris, improper waste disposal	3H		1L
12. Final inspection	identification of overlooked hazards, incomplete installation recognition	3H		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
13. Documentation and reporting	missed data leading to future risk, inaccurate record-keeping	2M		1L
14. De-briefing and feedback	missed learning opportunities, psychological stress from	2M		1L
15. Packing up and leaving site	tripping from unremoved barriers, damage to tools/equipment	2M		1L

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK
			<div></div> <div></div> <div></div> <div></div> <div></div> <div></div>	

SAMPLE

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES IF ANY STATE THAT ARE NOT APPLICABLE

Queensland & Australian Capital Territory

Work Health and Safety Act 2011

Work Health and Safety Regulations 2011

Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>

Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>

Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>

Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

Victoria

Occupational Health and Safety Act 2004

Occupational Health and Safety Regulations 2017

Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>

Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

New South Wales

Work Health and Safety Act 2011

Work Health and Safety Regulations 2017

Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>

Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-codes-of-practice>

Western Australia

Work Health and Safety Act 2020

Work Health and Safety Regulations 2022

Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>

Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

Northern Territory

Work Health and Safety (National Uniform Legislation) Act 2011

Work Health and Safety (National Uniform Legislation) Regulations 2011

Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplace-safety-laws>

Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

Safe Work Australia Links

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>

Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

Model Codes of Practice

- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

South Australia

Work Health and Safety Act 2012 (SA)

Work Health and Safety Regulations 2012 (SA)

Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>

Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

Tasmania

Work Health and Safety Act 2012

Work Health and Safety (Transitional and Consequential Provisions) Act 2012

Work Health and Safety Regulations 2012

Work Health and Safety (Transitional) Regulations 2012

Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>

Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.