

External Plumbing Water, Sewer & Gas | SAFE WORK METHOD STATEMENT (SWMS)

TASK OR ACTIVITY: External Plumbing Water, Sewer & Gas

Business Name: [Company Name]	ABN: [ABN]	SWMS#
Business Address: [Company Address]		
Contact Person:	Phone: [Phone]	Email:

THIS SAFE WORK METHOD STATEMENT IS APPROVED BY THE PCBU OF THE PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a safe work method statement (SWMS) is prepared before the proposed work starts.

Full Name:

Signature: _____ Title: _____ Date: _____

Details of the person(s) responsible for ensuring implementation, monitoring and compliance of the SWMS, as well as reviews and modifications of the SWMS.

Full Name: _____ Title: _____ Phone: _____

ALL PERSONNEL PARTICIPATING IN ANY ACTIVITY ON THIS SWMS MUST HAVE THE FOLLOWING COMMUNICATED | **NAME AND DATED SIGNATURE OF ALL RELEVANT PERSONNEL WHO HAVE BEEN CONSULTED AND COMMUNICATED TO IN THE DEVELOPMENT AND APPROVAL OF THIS SWMS**

	NAME	SIGNATURE	DATE
Safety meetings or toolbox talks will be scheduled in accordance with legislative requirements to first identify any site hazards, to conduct and communicate those hazards and then to further take steps to either eliminate or control each hazard.			
If an incident or a near miss occurs, all work must stop immediately. Depending on the severity of the incident, a meeting will be called with all workers to amend the SWMS if required. The meeting may also be an educational opportunity.			
Any changes made to the SWMS after an incident or a near miss must be approved by the Person Conducting Business or Undertaking and communicated to all relevant personnel.			
The SWMS must be kept and be available for inspection at least until the work is completed. Where a SWMS is revised, all versions should be kept. If a notifiable incident occurs in relation to which the SWMS relates, then the SWMS must be kept for at least two years from the occurrence of the notifiable incident.			

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

Client:	SCOPE OF WORKS Provide a detailed description of the specific work being carried out (otherwise known as scope of works).
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Project Manager Signature:	
Date SWMS supplied to Project Manager:	

ANY HIGH-RISK CONSTRUCTION WORK BEING CARRIED OUT

<input type="checkbox"/> involves a risk of a person falling more than 2 meters.	<input type="checkbox"/> is carried out on or near pressurised gas mains or piping.
<input type="checkbox"/> is carried out on a telecommunication tower.	<input type="checkbox"/> is carried out on or near chemical, fuel or refrigerant lines.
<input type="checkbox"/> involves demolition of an element of a structure that is load-bearing.	<input type="checkbox"/> is carried out on or near energised electrical installations or services.
<input type="checkbox"/> involves demolition of an element related to the physical integrity of a structure.	<input type="checkbox"/> is carried out in an area that may have a contaminated or flammable atmosphere.
<input type="checkbox"/> involves, or is likely to involve, disturbing asbestos.	<input type="checkbox"/> involves tilt-up or precast concrete.
<input type="checkbox"/> involves structural alteration or repair that requires temporary supports to prevent collapse.	<input type="checkbox"/> is carried out on, in or adjacent to a road, railway, shipping lane or other traffic corridor.
<input type="checkbox"/> is carried out in or near a confined space.	<input type="checkbox"/> is carried out in an area of a workplace where there is any movement of powered mobile plant.
<input type="checkbox"/> is carried out in/near a shaft or trench deeper than 1.5m or tunnel involving use of explosives.	<input type="checkbox"/> is carried out in areas with artificial extremes of temperature.
<input type="checkbox"/> is carried out in or near water or other liquid that involves a risk of drowning.	<input type="checkbox"/> involves diving work.

ANY HIGH-RISK MACHINERY OR EQUIPMENT NEARBY

<input type="checkbox"/> Forklift	<input type="checkbox"/> Crane/s	<input type="checkbox"/> Hoist/s	<input type="checkbox"/> Excavator	<input type="checkbox"/> Backhoe/Loader	<input type="checkbox"/> Boom Lift	<input type="checkbox"/> EWP	<input type="checkbox"/> Genie Lift
<input type="checkbox"/> Trencher	<input type="checkbox"/> Drilling Rig	<input type="checkbox"/> Trucks	<input type="checkbox"/> Formwork	<input type="checkbox"/> Bobcat	<input type="checkbox"/> Flammable Gas	<input type="checkbox"/> Fuel	<input type="checkbox"/> Dozer
<input type="checkbox"/> High Voltage	<input type="checkbox"/> Mulcher	<input type="checkbox"/> Tilt-up Panels	<input type="checkbox"/> Roller	<input type="checkbox"/> Scissor Lift	<input type="checkbox"/> Tractor	<input type="checkbox"/> Other -	

RISK MATRIX										
LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HEIRARCHY OF CONTROLS		
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			Elimination Remove the hazard.		
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	Substitution Replace the hazard.		
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	Isolation Isolate People from the hazard		
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	Engineering Isolate the hazard.		
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records	Administrative Change the work.		
								PPE		

Notes on Hierarchy of Controls: Elimination methods are the most effective and preferred when controlling a hazard. Substitution is the second most effective method of controlling a hazard. Engineering by isolation is the third most effective, while Administrative Controls by changing the work is the fourth most effective method. PPE (Personal Protective Equipment) is the least effective method.

PERSONAL PROTECTIVE EQUIPMENT (PPE)											
FOOT PROTECTION	HAND PROTECTION	HEAD PROTECTION	HEARING PROTECTION	EYE/FACE PROTECTION	RESPIRATORY PROTECTION	FACE PROTECTION	HIGH-VIS CLOTHING	PROTECTIVE CLOTHING	FALL PROTECTION	SUN PROTECTION	HAIR/JEWELLERY SECURED
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Select the appropriate PPE above suitable for the equipment used or the job task being performed (if applicable).

Note: A SWMS must be reviewed regularly to make sure it remains effective. A SWMS must be reviewed (and revised if necessary) if relevant control measures are revised. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When a SWMS has been revised, the person conducting a business or undertaking must ensure all:

- persons involved in the work are advised that a revision has been made and how they can access the revised SWMS;
- persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS; and,
- workers that will be involved in the work are provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
1. Preparation	Slip, trip and fall hazards, manual handling injuries	3H	<ul style="list-style-type: none"> - Implement site-specific risk assessments and safety plans prior to starting work, ensuring all workers understand potential hazards and necessary control measures. - Properly housekeep and maintain the work area, including regular cleaning to remove spillages, debris, or loose material that may cause slip, trip, and fall hazards. - Clear pathways, stairs, and ramps of obstructions, providing workers with adequate space to operate equipment and move around the site safely. - Ensure all personnel wear appropriate personal protective equipment (PPE) such as slip-resistant footwear, gloves, or manual handling tools, and any other gear recommended for the specific task. - Use mechanical lifting aids, such as pallets or hoists, as much as possible to minimize manual handling efforts and reduce the risk of muscle strains and sprains. - Educate workers on proper lifting techniques and body mechanics when handling heavy or bulky items, enforce a team lifting policy when necessary. - Mark out and designate specific areas/safety zones for machinery and vehicle movements, ensuring pedestrians are separated from the potential risk of being hit by machinery or vehicles. - Install temporary barriers or warning signs in the event of uneven surfaces, changes in elevation, or temporary excavation works to alert employees to potential slip and trip hazards. - Conduct regularly scheduled safety meetings and toolbox talks, emphasising the importance of maintaining a safe working environment and discussing best practices for hazard awareness and mitigating risks. - Encourage workers to report any unsafe conditions or near-miss incidents immediately to site supervisors or management, so that they can be addressed promptly to prevent accidents or injuries. 	1L	
2. Site Assessment	Unexpected utilities strike, exposure to contaminants	3H	<ul style="list-style-type: none"> - Obtain up-to-date utility maps and records: Before starting any work, gather current information on the locations of all underground utilities on the site to minimise the chances of unexpected strikes. This information can be sourced from local authorities or utility companies. - Conduct a thorough site inspection: Physically inspect the work zone to ensure there are no visible signs of other hazards or potential underground utilities that may not be accounted for on plans. - Utilise ground-penetrating radar (GPR): Employ GPR technology to assist in locating non-metallic utilities and confirming the position of any previously identified utilities. - Implement a safe excavation method: Develop and implement a safe excavation process, which includes hand digging or vacuum excavation as appropriate, to reduce the risk of accidental strikes when exposing utilities. 	2M	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> - Use barriers and warning signs: Set up clear demarcation around the worksite using barrier tape, cones, and warning signs to inform personnel and visitors of potential hazards. - Train workers on hazard awareness: Ensure that all employees involved in the project understand the risks associated with unexpected utilities strikes and exposure to contaminants. Provide adequate training and resources for them to respond to any issues promptly and safely. - Establish contingency plans: Prepare emergency response procedures that outline the immediate steps to be taken in the event of an unexpected utility strike or exposure to contaminants, including first aid strategies and evacuation processes. - Use personal protective equipment (PPE): Require all workers to wear suitable PPE such as gloves, safety goggles, high-visibility clothing, and hard hats to mitigate risks associated with the identified hazards. - Maintain regular communication: Encourage open channels of communication among team members during site inspections, status updates, and throughout the project duration to discuss potential risks and preventative measures. - Monitor site conditions: Continuously assess site conditions throughout the course of the project to identify any new or changing hazards. - Store and handle hazardous materials responsibly: Ensure all hazardous substances, including potential contaminants, are stored, transported, and disposed according to regulations, guidelines, and best practices. - Conduct toolbox talks and safety briefings: Regularly review the identified hazards and control measures with all team members through toolbox talks or safety briefings, ensuring all workers understand their roles and responsibilities in maintaining a safe worksite. 		
3. Excavation	Collapse of trench walls, damage to underground utilities	4A	<ul style="list-style-type: none"> - Perform a thorough risk assessment before initiating any excavation work to identify potential hazards and implement suitable control measures. - Obtain underground utility maps and other relevant information from relevant authorities and utility providers to mark out the location of underground services in the area to be excavated. - Use appropriate equipment such as cable avoidance tools (CAT) and ground-penetrating radar (GPR) to verify the exact location of underground utilities, ensuring no accidental damage is caused during excavation. - Employ trained and competent personnel to conduct excavation work, ensuring they are aware of all potential hazards and safe work practices. - Establish clearly marked exclusion zones around the excavation area, restricting access to authorised staff members only - this may include barrier tapes, signage, or temporary fencing. 	2M	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> - Ensure the use of proper shoring, trench shielding or benching systems to prevent collapse of trench walls, in accordance with local regulations and manufacturer's guidelines. - Conduct regular inspections of the excavation site by a competent person, noting changes in soil conditions or weather that may impact the stability of trench walls and implementing corrective actions as needed. - Maintain a safe working distance between the edge of the excavation and any equipment, materials, spoil piles or other hazards to minimise the risk of accidental falls or equipment sliding into the trench. - Develop emergency response plans for potential excavation incidents, including rescue procedures and equipment needed for rapid extraction of trapped workers. - Communicate with all stakeholders, including clients, subcontractors, and workers on-site about the excavation activities, who is involved, and the control measures put in place to maintain safety throughout the project. - Ensure all workers involved in excavation operations receive ongoing training and instruction regarding the work step and hazards, so they are equipped with the knowledge and skills to perform their tasks safely, and effectively mitigate the identified risks. 		
4. Pipe Installation	Falling objects, manual handling injuries	3H	<p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p>	2M	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
5. Leak Detection	Asphyxiation from gas leak, burns from flammable gases	3H	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
6. Backfilling	Buried utilities damage, soil compaction errors	2M	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
9. Valve Installation	Struck by moving equipment, manual handling injuries	3H	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
10. Final Inspection	Unsafe equipment use, incomplete work	2M	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
11. Site Clean-up	Slip, trip and fall hazards, disposal of hazardous waste	2M	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
12. Documentation & Sign-off	Incorrect record keeping, missed hazard reporting	2M	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES FOR ANY STATE THAT ARE NOT APPLICABLE

Queensland & Australian Capital Territory

Work Health and Safety Act 2011
 Work Health and Safety Regulations 2011
 Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>
 Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>
 Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>
 Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

Victoria

Occupational Health and Safety Act 2004
 Occupational Health and Safety Regulations 2017
 Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>
 Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

New South Wales

Work Health and Safety Act 2011
 Work Health and Safety Regulations 2017
 Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>
 Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-of-codes-of-practice>

Western Australia

Work Health and Safety Act 2020
 Work Health and Safety Regulations 2022
 Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>
 Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

Northern Territory

Work Health and Safety (National Uniform Legislation) Act 2011
 Work Health and Safety (National Uniform Legislation) Regulations 2011
 Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplaces-and-laws>
 Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

Safe Work Australia Links

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>
 Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

South Australia

Work Health and Safety Act 2012 (SA)
 Work Health and Safety Regulations 2012 (SA)
 Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>
 Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

Model Codes of Practice

- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

Tasmania

Work Health and Safety Act 2012
 Work Health and Safety (Transitional and Consequential Provisions) Act 2012
 Work Health and Safety Regulations 2012
 Work Health and Safety (Transitional) Regulations 2012
 Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>
 Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.

SIGNATORIES OF THE SAFE WORK METHOD STATEMENT

The signed and dated personnel listed below have cooperated in the consultation and development of this Safe Work Method Statement which has been approved by the Person/s Conducting a Business or Undertaking (PCBU). In signing this Safe Work Method Statement each individual acknowledges and confirms that they have read this SWMS in full, having raised any questions for items on this Safe Work Method Statement that require clarification, and confirms that they are competent, skilled and knowledgeable for the task assigned to them. Every person acknowledges that they have received the relevant training and qualifications where required, before carrying out any work contained in this Safe Work Method Statement. By signing this Safe Work Method Statement each individual agrees to work safely, to follow any safe work instructions which are provided, and agrees to use all Personal Protective Equipment where appropriate.

Worker Name	Position	Signature	Date	Time	Supervisor
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		

SAFE WORK METHOD STATEMENT MONITORING AND REVIEW

The SWMS must be reviewed regularly to make sure it remains effective and must be reviewed (and revised if necessary) if relevant control measures are needed. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When the SWMS has been revised the PCBU must ensure that all persons involved with the work are advised that a revision has been made and how they can access the revised SWMS, including all persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS. All workers that will be involved in the work must be provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

The SWMS must be monitored regularly for the effectiveness of ensuring hazard controls are effective in reducing the risk of incidents, keeping the workplace safe for all personnel. The person responsible for monitoring the effectiveness of the Safe Work Method Statement should employ a multi-faceted approach which includes but is not limited to:

1. Spot Checks.
2. Consultation with workers, contractors and sub-contractors.
3. Internal audits on a continual basis.

An approach of continuous improvement, promptly recording inconsistencies or deficiencies, followed up by immediate corrective action and consultation with all relevant personnel ensures that the PCBU is consistently developing ever-improving systems of safe work principles.

REVIEW NUMBER	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7
NAME							
INITIALS							
DATE							

SAFE WORK METHOD STATEMENT REVIEW CHECKLIST			
This Safe Work Method Statement Review Checklist is to be followed and used upon initial development of the SWMS to help ensure that all steps have been adequately taken before work commences. Think of this document as an internal audit review checklist before commencing work, and may form part of a Toolbox Talk (safety meeting) and may be used as an opportunity for education and training.			
ITEMS WHICH MUST BE INCLUDED IN THE SWMS	COMPLETED	TO BE DONE	COMMENTS
The company details have been entered, including the project name and address.	<input type="checkbox"/>	<input type="checkbox"/>	
Names and signatures of all relevant personnel consulted during the development of the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Name, signature, position and date signed of the person approving the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Specific personnel and qualifications, experience is noted in the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Provides a step-by-step process of tasks required to carry out the activity or task.	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate risk assessment of any identified hazards has been completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Foreseeable hazards are identified and documented for each step.	<input type="checkbox"/>	<input type="checkbox"/>	
Any hazards listed in any site risk assessments have been added to the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS initial risk (IR) column as well as residual risk (RR) columns completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Check control measures added to the SWMS are the most effective solutions.	<input type="checkbox"/>	<input type="checkbox"/>	
Responsible person is assigned and listed on the SWMS for the implementation of control measures.	<input type="checkbox"/>	<input type="checkbox"/>	
Permit requirements specified, such as Hot Work, Electrical Work, Work at Heights etc.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS identifies plant and equipment to be used.	<input type="checkbox"/>	<input type="checkbox"/>	
Details of inspection checks required for any equipment listed are noted on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Describes any mandatory qualifications, experience, training, skills required to perform the work.	<input type="checkbox"/>	<input type="checkbox"/>	
Applicable personal protective equipment is selected on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Lists any required permits or licenses.	<input type="checkbox"/>	<input type="checkbox"/>	
Reflects and documents any legislative references and/or Australian Standards.	<input type="checkbox"/>	<input type="checkbox"/>	
Identifies any hazardous substances used with specific control measures in line with any SDS.	<input type="checkbox"/>	<input type="checkbox"/>	
REVIEWED BY		DATE REVIEWED	
SIGNATURE		DATE COMPLETED	