

**Gas Cylinders Storage And Handling | SAFE WORK METHOD STATEMENT (SWMS)**

**TASK OR ACTIVITY: Gas Cylinders Storage And Handling**

Business Name: [Company Name] ABN: [ABN] SWMS#

Business Address: [Company Address]

Contact Person: Phone: [Phone] Email:

**THIS SAFE WORK METHOD STATEMENT IS APPROVED BY THE PCBU OF THE PROJECT**

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a safe work method statement (SWMS) is prepared before the proposed work starts.

Full Name:

Signature: Title: Date:

Details of the person(s) responsible for ensuring implementation, monitoring and compliance of the SWMS, as well as reviews and modifications of the SWMS.

Full Name: Title: Phone:

**ALL PERSONNEL PARTICIPATING IN ANY ACTIVITY ON THIS SWMS MUST HAVE THE FOLLOWING COMMUNICATED** NAME AND DATED SIGNATURE OF ALL RELEVANT PERSONNEL WHO HAVE BEEN CONSULTED AND COMMUNICATED TO IN THE DEVELOPMENT AND APPROVAL OF THIS SWMS

	NAME	SIGNATURE	DATE
Safety meetings or toolbox talks will be scheduled in accordance with legislative requirements to first identify any site hazards, to conduct and communicate those hazards and then to further take steps to either eliminate or control each hazard.			
If an incident or a near miss occurs, all work must stop immediately. Depending on the severity of the incident, a meeting will be called with all workers to amend the SWMS if required. The meeting may also be an educational opportunity.			
Any changes made to the SWMS after an incident or a near miss must be approved by the Person Conducting Business or Undertaking and communicated to all relevant personnel.			
The SWMS must be kept and be available for inspection at least until the work is completed. Where a SWMS is revised, all versions should be kept. If a notifiable incident occurs in relation to which the SWMS relates, then the SWMS must be kept for at least two years from the occurrence of the notifiable incident.			

**CLIENT OR PRINCIPAL CONTRACTOR DETAILS**

Client:	SCOPE OF WORKS Provide a detailed description of the specific work being carried out (otherwise known as scope of works).
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Project Manager Signature:	
Date SWMS supplied to Project Manager:	

**ANY HIGH-RISK CONSTRUCTION WORK BEING CARRIED OUT**

<input type="checkbox"/> involves a risk of a person falling more than 2 meters.	<input type="checkbox"/> is carried out on or near pressurised gas mains or piping.
<input type="checkbox"/> is carried out on a telecommunication tower.	<input type="checkbox"/> is carried out on or near chemical, fuel or refrigerant lines.
<input type="checkbox"/> involves demolition of an element of a structure that is load-bearing.	<input type="checkbox"/> is carried out on or near energised electrical installations or services.
<input type="checkbox"/> involves demolition of an element related to the physical integrity of a structure.	<input type="checkbox"/> is carried out in an area that may have a contaminated or flammable atmosphere.
<input type="checkbox"/> involves, or is likely to involve, disturbing asbestos.	<input type="checkbox"/> involves tilt-up or precast concrete.
<input type="checkbox"/> involves structural alteration or repair that requires temporary supports to prevent collapse.	<input type="checkbox"/> is carried out on, in or adjacent to a road, railway, shipping lane or other traffic corridor.
<input type="checkbox"/> is carried out in or near a confined space.	<input type="checkbox"/> is carried out in an area of a workplace where there is any movement of powered mobile plant.
<input type="checkbox"/> is carried out in/near a shaft or trench deeper than 1.5m or tunnel involving use of explosives.	<input type="checkbox"/> is carried out in areas with artificial extremes of temperature.
<input type="checkbox"/> is carried out in or near water or other liquid that involves a risk of drowning.	<input type="checkbox"/> involves diving work.

**ANY HIGH-RISK MACHINERY OR EQUIPMENT NEARBY**

<input type="checkbox"/> Forklift	<input type="checkbox"/> Crane/s	<input type="checkbox"/> Hoist/s	<input type="checkbox"/> Excavator	<input type="checkbox"/> Backhoe/Loader	<input type="checkbox"/> Boom Lift	<input type="checkbox"/> EWP	<input type="checkbox"/> Genie Lift
<input type="checkbox"/> Trencher	<input type="checkbox"/> Drilling Rig	<input type="checkbox"/> Trucks	<input type="checkbox"/> Formwork	<input type="checkbox"/> Bobcat	<input type="checkbox"/> Flammable Gas	<input type="checkbox"/> Fuel	<input type="checkbox"/> Dozer
<input type="checkbox"/> High Voltage	<input type="checkbox"/> Mulcher	<input type="checkbox"/> Tilt-up Panels	<input type="checkbox"/> Roller	<input type="checkbox"/> Scissor Lift	<input type="checkbox"/> Tractor	<input type="checkbox"/> Other -	

RISK MATRIX										
LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HEIRARCHY OF CONTROLS		
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			<b>Elimination</b> Remove the hazard.		
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	<b>Substitution</b> Replace the hazard.		
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	<b>Isolation</b> Isolate People from the hazard		
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	<b>Engineering</b> Isolate the hazard.		
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records	<b>Administrative</b> Change the work.		
								<b>PPE</b>		

**Notes on Hierarchy of Controls:** Elimination methods are the most effective and preferred when controlling a hazard. Substitution is the second most effective method of controlling a hazard. Engineering by isolation is the third most effective, while Administrative Controls by changing the work is the fourth most effective method. PPE (Personal Protective Equipment) is the least effective method.

PERSONAL PROTECTIVE EQUIPMENT (PPE)											
FOOT PROTECTION	HAND PROTECTION	HEAD PROTECTION	HEARING PROTECTION	EYE/FACE PROTECTION	RESPIRATORY PROTECTION	FACE PROTECTION	HIGH-VIS CLOTHING	PROTECTIVE CLOTHING	FALL PROTECTION	SUN PROTECTION	HAIR/JEWELLERY SECURED
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Select the appropriate PPE above suitable for the equipment used or the job task being performed (if applicable).

**Note:** A SWMS must be reviewed regularly to make sure it remains effective. A SWMS must be reviewed (and revised if necessary) if relevant control measures are revised. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When a SWMS has been revised, the person conducting a business or undertaking must ensure all:

1. persons involved in the work are advised that a revision has been made and how they can access the revised SWMS;
2. persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS; and,
3. workers that will be involved in the work are provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
1. Preparation	Unsafe storage location, Inadequate cylinder restraints	2M	<ul style="list-style-type: none"> <li>- Select a suitable storage location, ensuring it is well-ventilated, free from ignition sources, and protected from extreme temperatures and direct sunlight.</li> <li>- Store gas cylinders in a designated area with appropriate signage indicating the presence of pressurised gases and any potential hazards.</li> <li>- Install anti-slip flooring in the storage areas to prevent accidental slippage when moving or handling cylinders.</li> <li>- Implement cylinder restraints such as securing chains, straps or purpose-built brackets, to prevent cylinders from falling or rolling in the storage area.</li> <li>- Utilise cylinder caps or guards on all stored cylinders to protect valve stems from accidental damage or activation.</li> <li>- Ensure that incompatible gases are stored separately, maintaining a minimum distance of 3 meters (10') between flammable and oxidizing gas cylinders.</li> <li>- Implement a first-in, first-out inventory system for gas cylinders, to ensure older cylinders are used before newer ones and decrease the risk of improper handling due to outdated equipment.</li> <li>- Regularly inspect and maintain cylinder storage facilities, including restraints and the storage environment, to ensure they remain effective and fit for purpose.</li> <li>- Train personnel involved in the handling and storage of gas cylinders regarding proper procedures, safety precautions, and emergency response protocols.</li> <li>- Establish an emergency response plan in case of gas leaks, fire, or other incidents involving stored gas cylinders, including regular drills and training for employees.</li> <li>- Encourage the use of personal protective equipment (such as heavy-duty gloves, safety glasses, and steel-toed boots) by staff when handling gas cylinders.</li> <li>- Regularly review and update the safety data sheets (SDS) for all gases stored on-site, ensuring staff have access to this information for reference and training purposes.</li> <li>- Conduct routine audits to monitor compliance with safety regulations, as well as the effectiveness of established control measures, adjusting them as necessary to maintain a safe working environment.</li> </ul>	1L	
2. Cylinder Inspection	Damaged cylinders, Leaking valves	3H	<ul style="list-style-type: none"> <li>- Regular visual inspections: Conduct routine visual examinations of gas cylinders for any signs of damage, such as dents, gouges, rust, or signs of heat exposure.</li> <li>- Proper signage and labeling: Ensure all gas cylinders are clearly labelled with their contents and hazard classification, in accordance with relevant regulations.</li> <li>- Trained personnel: Only allow trained and authorised individuals to handle and inspect gas cylinders.</li> </ul>	1L	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> <li>- Use of personal protective equipment (PPE): Require workers handling gas cylinders to wear appropriate PPE, including gloves, eye protection, and closed-toe shoes.</li> <li>- Leak detection methods: Implement proper leak detection methods, such as conducting pressure tests or using a soapy water solution to check for leaking valves during inspection.</li> <li>- Integrity of cylinder: Verify the integrity and expiration date of gas cylinders according to the manufacturer's recommendations and regulatory requirements.</li> <li>- Appropriate storage conditions: Store gas cylinders in designated areas away from direct sunlight, heat sources, moisture, and potential ignition sources, complying with storage guidelines for respective gases.</li> <li>- Proper handling procedures: Train workers on the appropriate handling techniques and usage of tools, such as hand trucks and cylinder carts, when moving gas cylinders.</li> <li>- Cylinder segregation: Segregate damaged or leaking cylinders from intact ones and mark them clearly to prevent accidental use.</li> <li>- Periodic maintenance: Perform periodic maintenance and servicing of cylinders by qualified technicians per the manufacturer's recommendations and regulatory requirements.</li> <li>- Reporting system: Establish a clear reporting mechanism for promptly notifying supervisors or managers of any damaged or leaking cylinders identified during the inspection process.</li> <li>- Emergency response plan: Develop and implement an emergency response plan specific to incidents involving gas cylinders, ensuring that all workers are familiar with their roles and responsibilities.</li> <li>- Disposal of damaged cylinders: Dispose of damaged or non-compliant gas cylinders according to appropriate disposal guidelines, handling procedures, and waste management practices.</li> <li>- Continuous improvement: Regularly review inspection practices, worker training programs, and risk management strategies to identify opportunities for improving gas cylinder safety in the workplace.</li> </ul>		
3. Moving Cylinders	Manual handling injuries, Struck by falling objects	3H	<ul style="list-style-type: none"> <li>- Conduct a risk assessment beforehand to identify potential hazards and determine appropriate control measures in accordance with relevant Australian Standards, Codes of Practice, and industry guidelines.</li> <li>- Provide appropriate Personal Protective Equipment (PPE) for workers, including gloves, safety footwear, and high-visibility clothing to minimise the risk of injury while handling gas cylinders.</li> <li>- Train workers in proper manual handling techniques, including how to lift, carry, push, and pull gas cylinders, as well as the correct use of handling equipment like trolleys or cranes.</li> </ul>	2M	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> <li>- Perform regular maintenance and inspection of cylinder handling equipment to ensure it's in good working order and fit for purpose.</li> <li>- Implement an appropriate storage system for all gas cylinders, ensuring that they are clearly labelled and secured using appropriate restraining devices such as cylinder clamps or chains.</li> <li>- Establish a clear procedure for transporting gas cylinders within the work area, including designated routes, speed limits, and clear ways to avoid collisions or accidents.</li> <li>- Ensure any lifting or moving is performed only by trained and competent personnel, using dedicated equipment designed specifically for handling gas cylinders.</li> <li>- Avoid stacking gas cylinders too high and keep heavy or larger cylinders on lower levels to reduce the risk of falling objects.</li> <li>- Utilise designated cylinder loading and unloading zones, making sure these areas are kept clear from obstructions and properly marked with signage to limit the likelihood of accidents.</li> <li>- Keep empty cylinders separated from full ones, as well as incompatible gases stored separately to prevent accidental leakages, mixing, or other hazardous situations.</li> <li>- Implement a routine inspection schedule to check for signs of damage or leaks on gas cylinders, ensuring timely detection and mitigation of potential hazards.</li> <li>- Encourage open communication and reporting between workers and supervisors regarding any concerns about the storage and handling process, including identifying potential hazards and near misses.</li> <li>- Continually review and update workplace policies, procedures, and training materials related to the moving, storage, and handling of gas cylinders, ensuring that they stay current with industry best practices and any relevant legislative changes.</li> </ul>		
4. Connecting Regulators	Incorrect connection, Gas leaks	3H	<p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p>	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
5. Opening Cylinder Valves	High-pressure gas release, Valve failure	4A	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
6. Igniting the Gas	Uncontrolled ignition, Fire hazard	3H	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		

SAMPLE



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
7. Operating Equipment	Improper use, Malfunctioning equipment	2M	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
8. Cylinder Replacement	Disconnecting regulator, Exposure to high-pressure gas	3H	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
9. Emergency Response	Delayed response, Lack of proper training	2M	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
10. Ventilation Assessment	Insufficient ventilation, Accumulation of gas	2M	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
11. Cylinder Transportation	Insecure load, Vehicle collision	3H	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
12. Cylinder Disposal	Unauthorised disposal, Hazardous waste exposure	1L	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

**EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES**

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

**LEGISLATIVE REFERENCES**

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES FOR ANY STATE THAT ARE NOT APPLICABLE

**Queensland & Australian Capital Territory**

Work Health and Safety Act 2011  
 Work Health and Safety Regulations 2011  
 Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>  
 Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>  
 Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>  
 Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

**Victoria**

Occupational Health and Safety Act 2004  
 Occupational Health and Safety Regulations 2017  
 Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>  
 Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

**New South Wales**

Work Health and Safety Act 2011  
 Work Health and Safety Regulations 2017  
 Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>  
 Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-of-codes-of-practice>

**Western Australia**

Work Health and Safety Act 2020  
 Work Health and Safety Regulations 2022  
 Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>  
 Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

**Northern Territory**

Work Health and Safety (National Uniform Legislation) Act 2011  
 Work Health and Safety (National Uniform Legislation) Regulations 2011  
 Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplaces-and-laws>  
 Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

**Safe Work Australia Links**

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>  
 Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

**South Australia**

Work Health and Safety Act 2012 (SA)  
 Work Health and Safety Regulations 2012 (SA)  
 Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>  
 Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

**Model Codes of Practice**


- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

**Tasmania**

Work Health and Safety Act 2012  
 Work Health and Safety (Transitional and Consequential Provisions) Act 2012  
 Work Health and Safety Regulations 2012  
 Work Health and Safety (Transitional) Regulations 2012  
 Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>  
 Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.





**SIGNATORIES OF THE SAFE WORK METHOD STATEMENT**

The signed and dated personnel listed below have cooperated in the consultation and development of this Safe Work Method Statement which has been approved by the Person/s Conducting a Business or Undertaking (PCBU). In signing this Safe Work Method Statement each individual acknowledges and confirms that they have read this SWMS in full, having raised any questions for items on this Safe Work Method Statement that require clarification, and confirms that they are competent, skilled and knowledgeable for the task assigned to them. Every person acknowledges that they have received the relevant training and qualifications where required, before carrying out any work contained in this Safe Work Method Statement. By signing this Safe Work Method Statement each individual agrees to work safely, to follow any safe work instructions which are provided, and agrees to use all Personal Protective Equipment where appropriate.

Worker Name	Position	Signature	Date	Time	Supervisor
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		

**SAFE WORK METHOD STATEMENT MONITORING AND REVIEW**

**The SWMS must be reviewed regularly** to make sure it remains effective and must be reviewed (and revised if necessary) if relevant control measures are needed. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When the SWMS has been revised the PCBU must ensure that all persons involved with the work are advised that a revision has been made and how they can access the revised SWMS, including all persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS. All workers that will be involved in the work must be provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

**The SWMS must be monitored regularly** for the effectiveness of ensuring hazard controls are effective in reducing the risk of incidents, keeping the workplace safe for all personnel. The person responsible for monitoring the effectiveness of the Safe Work Method Statement should employ a multi-faceted approach which includes but is not limited to:

1. Spot Checks.
2. Consultation with workers, contractors and sub-contractors.
3. Internal audits on a continual basis.

An approach of continuous improvement, promptly recording inconsistencies or deficiencies, followed up by immediate corrective action and consultation with all relevant personnel ensures that the PCBU is consistently developing ever-improving systems of safe work principles.

REVIEW NUMBER	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7
NAME							
INITIALS							
DATE							

SAFE WORK METHOD STATEMENT REVIEW CHECKLIST			
This Safe Work Method Statement Review Checklist is to be followed and used upon initial development of the SWMS to help ensure that all steps have been adequately taken before work commences. Think of this document as an internal audit review checklist before commencing work, and may form part of a Toolbox Talk (safety meeting) and may be used as an opportunity for education and training.			
ITEMS WHICH MUST BE INCLUDED IN THE SWMS	COMPLETED	TO BE DONE	COMMENTS
The company details have been entered, including the project name and address.	<input type="checkbox"/>	<input type="checkbox"/>	
Names and signatures of all relevant personnel consulted during the development of the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Name, signature, position and date signed of the person approving the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Specific personnel and qualifications, experience is noted in the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Provides a step-by-step process of tasks required to carry out the activity or task.	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate risk assessment of any identified hazards has been completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Foreseeable hazards are identified and documented for each step.	<input type="checkbox"/>	<input type="checkbox"/>	
Any hazards listed in any site risk assessments have been added to the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS initial risk (IR) column as well as residual risk (RR) columns completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Check control measures added to the SWMS are the most effective solutions.	<input type="checkbox"/>	<input type="checkbox"/>	
Responsible person is assigned and listed on the SWMS for the implementation of control measures.	<input type="checkbox"/>	<input type="checkbox"/>	
Permit requirements specified, such as Hot Work, Electrical Work, Work at Heights etc.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS identifies plant and equipment to be used.	<input type="checkbox"/>	<input type="checkbox"/>	
Details of inspection checks required for any equipment listed are noted on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Describes any mandatory qualifications, experience, training, skills required to perform the work.	<input type="checkbox"/>	<input type="checkbox"/>	
Applicable personal protective equipment is selected on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Lists any required permits or licenses.	<input type="checkbox"/>	<input type="checkbox"/>	
Reflects and documents any legislative references and/or Australian Standards.	<input type="checkbox"/>	<input type="checkbox"/>	
Identifies any hazardous substances used with specific control measures in line with any SDS.	<input type="checkbox"/>	<input type="checkbox"/>	
<b>REVIEWED BY</b>		<b>DATE REVIEWED</b>	
<b>SIGNATURE</b>		<b>DATE COMPLETED</b>	