

**Rigging Work (Basic) | SAFE WORK METHOD STATEMENT (SWMS)**

**TASK OR ACTIVITY: Rigging Work (Basic)**

Business Name: [Company Name]	ABN: [ABN]	SWMS#
Business Address: [Company Address]		
Contact Person:	Phone: [Phone]	Email:

**THIS SAFE WORK METHOD STATEMENT IS APPROVED BY THE PROJECT MANAGER OF THE PROJECT**

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a safe work method statement (SWMS) is prepared before the proposed work starts.

Full Name:

Signature: \_\_\_\_\_ Title: \_\_\_\_\_ Date: \_\_\_\_\_

Details of the person(s) responsible for ensuring implementation, monitoring and compliance of the SWMS, as well as reviews and modifications of the SWMS.

Full Name: \_\_\_\_\_ Title: \_\_\_\_\_ Phone: \_\_\_\_\_

**ALL PERSONNEL PARTICIPATING IN ANY ACTIVITY ON THIS SWMS MUST HAVE THE FOLLOWING COMMUNICATED**

**NAME AND DATED SIGNATURE OF ALL RELEVANT PERSONNEL WHO HAVE BEEN CONSULTED AND COMMUNICATED TO IN THE DEVELOPMENT AND APPROVAL OF THIS SWMS**

	NAME	SIGNATURE	DATE
Safety meetings or toolbox talks will be scheduled in accordance with legislative requirements to first identify any site hazards, then to communicate those hazards and then to further take steps to either eliminate or control each hazard.			
If an incident or a near miss occurs, all work must stop immediately. Depending on the severity of the incident, a meeting will be called with all workers to amend the SWMS if required. The meeting may also be an educational opportunity.			
Any changes made to the SWMS after an incident or a near miss must be approved by the Person Conducting Business or Undertaking and communicated to all relevant personnel.			
The SWMS must be kept and be available for inspection at least until the work is completed. Where a SWMS is revised, all versions should be kept. If a notifiable incident occurs in relation to which the SWMS relates, then the SWMS must be kept for at least two years from the occurrence of the notifiable incident.			

**CLIENT OR PRINCIPAL CONTRACTOR DETAILS**

Client:	SCOPE OF WORKS Provide a detailed description of the specific work being carried out (otherwise known as scope of works).
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Project Manager Signature:	
Date SWMS supplied to Project Manager:	

**ANY HIGH-RISK CONSTRUCTION WORK BEING CARRIED OUT**

<input type="checkbox"/> involves a risk of a person falling more than 2 meters.	<input type="checkbox"/> is carried out on or near pressurised gas mains or piping.
<input type="checkbox"/> is carried out on a telecommunication tower.	<input type="checkbox"/> is carried out on or near chemical, fuel or refrigerant lines.
<input type="checkbox"/> involves demolition of an element of a structure that is load-bearing.	<input type="checkbox"/> is carried out on or near energised electrical installations or services.
<input type="checkbox"/> involves demolition of an element related to the physical integrity of a structure.	<input type="checkbox"/> is carried out in an area that may have a contaminated or flammable atmosphere.
<input type="checkbox"/> involves, or is likely to involve, disturbing asbestos.	<input type="checkbox"/> involves tilt-up or precast concrete.
<input type="checkbox"/> involves structural alteration or repair that requires temporary supports to prevent collapse.	<input type="checkbox"/> is carried out on, in or adjacent to a road, railway, shipping lane or other traffic corridor.
<input type="checkbox"/> is carried out in or near a confined space.	<input type="checkbox"/> is carried out in an area of a workplace where there is any movement of powered mobile plant.
<input type="checkbox"/> is carried out in/near a shaft or trench deeper than 1.5m or tunnel involving use of explosives.	<input type="checkbox"/> is carried out in areas with artificial extremes of temperature.
<input type="checkbox"/> is carried out in or near water or other liquid that involves a risk of drowning.	<input type="checkbox"/> involves diving work.

**ANY HIGH-RISK MACHINERY OR EQUIPMENT NEARBY**

<input type="checkbox"/> Forklift	<input type="checkbox"/> Crane/s	<input type="checkbox"/> Hoist/s	<input type="checkbox"/> Excavator	<input type="checkbox"/> Backhoe/Loader	<input type="checkbox"/> Boom Lift	<input type="checkbox"/> EWP	<input type="checkbox"/> Genie Lift
<input type="checkbox"/> Trencher	<input type="checkbox"/> Drilling Rig	<input type="checkbox"/> Trucks	<input type="checkbox"/> Formwork	<input type="checkbox"/> Bobcat	<input type="checkbox"/> Flammable Gas	<input type="checkbox"/> Fuel	<input type="checkbox"/> Dozer
<input type="checkbox"/> High Voltage	<input type="checkbox"/> Mulcher	<input type="checkbox"/> Tilt-up Panels	<input type="checkbox"/> Roller	<input type="checkbox"/> Scissor Lift	<input type="checkbox"/> Tractor	<input type="checkbox"/> Other -	

RISK MATRIX										
LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HEIRARCHY OF CONTROLS		
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			<b>Elimination</b> Remove the hazard.		
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	<b>Substitution</b> Replace the hazard.		
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	<b>Isolation</b> Isolate People from the hazard		
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	<b>Engineering</b> Isolate the hazard.		
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records	<b>Administrative</b> Change the work.		
								<b>PPE</b>		

**Notes on Hierarchy of Controls:** Elimination methods are the most effective and preferred when controlling a hazard. Substitution is the second most effective method of controlling a hazard. Engineering by isolation is the third most effective, while Administrative Controls by changing the work is the fourth most effective method. PPE (Personal Protective Equipment) is the least effective method.

PERSONAL PROTECTIVE EQUIPMENT (PPE)											
FOOT PROTECTION	HAND PROTECTION	HEAD PROTECTION	HEARING PROTECTION	EYE/FACE PROTECTION	RESPIRATORY PROTECTION	FACE PROTECTION	HIGH-VIS CLOTHING	PROTECTIVE CLOTHING	FALL PROTECTION	SUN PROTECTION	HAIR/JEWELLERY SECURED
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Select the appropriate PPE above suitable for the equipment used or the job task being performed (if applicable).

**Note:** A SWMS must be reviewed regularly to make sure it remains effective. A SWMS must be reviewed (and revised if necessary) if relevant control measures are revised. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When a SWMS has been revised, the person conducting a business or undertaking must ensure all:

1. persons involved in the work are advised that a revision has been made and how they can access the revised SWMS;
2. persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS; and,
3. workers that will be involved in the work are provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
1. Preparation	Trip hazards, Incorrect equipment selection	2M	<ul style="list-style-type: none"> <li>- Conduct thorough site inspection: Prior to commencing work, carry out a comprehensive assessment of the worksite to identify possible trip hazards such as uneven surfaces, loose cables or materials, and remove or mitigate them accordingly.</li> <li>- Implement walkway management: Establish clearly demarcated walkways around the work area, keeping them free from obstruction and ensuring they are well-lit for ease of movement and navigation.</li> <li>- Equipment selection training: Provide appropriate training to workers about selecting and using the correct equipment for the specific rigging job, with consideration given to factors such as load capacity and environmental conditions.</li> <li>- Implement storage and housekeeping guidelines: Store all tools, equipment, and materials not in use in designated areas. Instruct workers to maintain a clean and organised worksite at all times to minimise the risk of trip hazards.</li> <li>- Use appropriate protective gear: Ensure that workers wear appropriate personal protective equipment (PPE), including non-slip footwear, hard hats, gloves, and safety vests to minimise injuries from potential hazards.</li> <li>- Develop an equipment inspection checklist: Regularly inspect all rigging equipment before and after use, checking for any signs of damage or defect, and ensure immediate replacement of any compromised equipment.</li> <li>- Establish communication protocols: Maintain proper communication between workers during all stages of the rigging process, utilising hand signals, radios, or other means to relay important information related to safety and addressing hazards efficiently.</li> <li>- Set load limits and safety guidelines: Clearly outline maximum load capacities for each piece of rigging equipment and provide workers with guidelines such as pre-lift load testing, to ensure safe and secure lifting operations.</li> <li>- Utilise safety barriers and signage: Erect safety barriers around the work zone to restrict access only to authorised personnel and display clear signage highlighting potential hazards, restricted areas, and mandatory PPE requirements.</li> <li>- Foster a safety culture: Encourage open communication and reporting of near-misses and hazards amongst workers, while consistently reinforcing the importance of safety and ongoing training to minimise risks associated with rigging work.</li> </ul>	1L	
2. PPE Inspection	Damaged/worn-out PPE, Inventory shortage	2M	<ul style="list-style-type: none"> <li>- Regular inspection of all Personal Protective Equipment (PPE) to ensure it is in proper working condition and free from any damage or wear and tear.</li> <li>- Implement a mandatory PPE inspection checklist for all workers before they start their shift; this will help identify any damaged or worn-out PPE that requires replacement.</li> <li>- Conduct training sessions for employees on performing PPE inspections and how to identify signs of wear, tear, and other potential defects.</li> </ul>	1L	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> <li>- Establish strong communication between workers and supervisors to report any damaged, worn-out, or insufficient PPE inventory as soon as possible.</li> <li>- Set up clear guidelines regarding the minimum standard of PPE required for specific tasks, and make sure the required PPE is readily available for all employees.</li> <li>- Ensure appropriate signage and documentation are placed throughout the worksite, providing information about the correct PPE to use for each task.</li> <li>- Develop a system to track and regularly update PPE inventory records, including the purchase, replacement, and disposal of equipment as needed.</li> <li>- Perform regular audits of the PPE inventory storage, ensuring proper storage conditions, preventing deterioration of the equipment and maintaining stock control.</li> <li>- Incorporate routine replacement plans for PPE; this helps guarantee that items haven't surpassed their lifespan and remain effective in protecting workers.</li> <li>- Encourage a culture of safety within the workplace through constant reminders about the importance of using, inspecting, and maintaining PPE.</li> <li>- Coordinate with PPE suppliers to ensure timely delivery of quality products, meeting the required safety standards according to the nature of work being performed.</li> <li>- Keep a backup PPE on-site to account for unexpected shortages and ensure that there's adequate inventory for every worker at all times.</li> <li>- Establish disciplinary measures for workers who fail to follow PPE inspection guidelines and procedures as a deterrent for negligent behaviour which can lead to increased health and safety risks.</li> </ul>		
3. Site Access	Uneven terrain, Obstructed entryways	2M	<ul style="list-style-type: none"> <li>- Clear and mark designated paths: Ensure that all entryways and access points to the site are free from obstructions and clearly marked to allow for safe movement of personnel and equipment.</li> <li>- Perform regular site inspections: Regularly inspect the site to identify any potential hazards, such as uneven terrain or obstructed entryways, and address them promptly.</li> <li>- Use proper footwear: All personnel should wear appropriate footwear with non-slip soles and adequate ankle support to minimise the risk of slips, trips, and falls on uneven terrain.</li> <li>- Provide adequate lighting: Ensure there's sufficient lighting in and around the site, especially near entryways and access points where potential hazards might be present.</li> <li>- Implement traffic control measures: Utilise signage, barriers, and trained flaggers to manage vehicle and pedestrian traffic, ensuring safe navigation through and around the work site.</li> </ul>	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> <li>- Designate specific access routes: Require all workers and visitors to follow designated access routes to minimise exposure to uneven terrain and other potential hazards.</li> <li>- Maintain safe egress routes: Ensure that emergency exit pathways are clear at all times and easily accessible in the event of an incident.</li> <li>- Educate workers on site-specific hazards: Conduct regular safety briefings to raise awareness on hazards associated with uneven terrain and obstructed entryways and discuss measures to mitigate those risks.</li> <li>- Encourage hazard reporting: Foster a culture where workers feel comfortable reporting hazards they encounter on-site, so they can be addressed promptly.</li> <li>- Provide suitable temporary walkways: Install mats, walkways, or stepping stones in areas with uneven terrain, making it easier and safer for workers to navigate the site.</li> <li>- Establish clear communication protocols: Set up efficient communication systems, such as two-way radios, to inform workers about changes in site conditions or access requirements.</li> <li>- Monitor weather conditions: Keep a close eye on the weather, particularly during the rainy season, when ground conditions and site access may be affected by mud, flooding, or other hazards. Adapt work actions if necessary to maintain safety.</li> </ul>		
4. Load Assessment	Incorrect weight estimation, Unbalanced load	3H	[REDACTED]	2M	

SAMPLE









JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
7. Crane Setup	Incorrect positioning, Component failure	3H	[REDACTED]	2M	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
8. Pre-Lift Safety Checks	Inadequate inspection with procedures	[REDACTED]	[REDACTED]	1L	[REDACTED]

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
9. Lifting Operation	Collapse of rigging hazards	4A	[REDACTED]	3H	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
10. Load Transport	Struck by moving load, Unsecured load	3H	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
11. Load Lowering	Release of tension, Personal injury	3H	[Redacted]	2M	
			[Redacted]		
			[Redacted]		

SAMPLE



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE



**EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES**

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

**LEGISLATIVE REFERENCES**

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES FOR ANY STATE THAT ARE NOT APPLICABLE

**Queensland & Australian Capital Territory**

Work Health and Safety Act 2011  
 Work Health and Safety Regulations 2011  
 Legislation QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws>  
 Codes of Practice QLD: <https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice>  
 Legislation ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations>  
 Codes of Practice ACT: <https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice>

**Victoria**

Occupational Health and Safety Act 2004  
 Occupational Health and Safety Regulations 2017  
 Legislation VIC: <https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations>  
 Codes of Practice VIC: <https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice>

**New South Wales**

Work Health and Safety Act 2011  
 Work Health and Safety Regulations 2017  
 Legislation NSW: <https://www.safework.nsw.gov.au/legal-obligations/legislation>  
 Codes of Practice NSW: <https://www.safework.nsw.gov.au/resource-library/list-of-codes-of-practice>

**Western Australia**

Work Health and Safety Act 2020  
 Work Health and Safety Regulations 2022  
 Legislation Western Australia: <https://www.commerce.wa.gov.au/worksafe/legislation>  
 Codes of Practice WA: <https://www.commerce.wa.gov.au/worksafe/codes-practice>

**Northern Territory**

Work Health and Safety (National Uniform Legislation) Act 2011  
 Work Health and Safety (National Uniform Legislation) Regulations 2011  
 Legislation NT: <https://worksafe.nt.gov.au/laws-and-compliance/workplaces-and-laws>  
 Codes of Practice NT: <https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice>

**Safe Work Australia Links**

Law and Regulation (All States): <https://www.safeworkaustralia.gov.au/law-and-regulation>  
 Model Codes of Practice: <https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice>

**South Australia**

Work Health and Safety Act 2012 (SA)  
 Work Health and Safety Regulations 2012 (SA)  
 Legislation for SA: <https://www.safework.sa.gov.au/resources/legislation>  
 Codes of Practice for SA: <https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs>

**Model Codes of Practice**


- Managing noise and preventing hearing loss at work
- Confined spaces
- Labelling of workplace hazardous chemicals
- Managing risks of hazardous chemicals in the workplace
- Welding processes
- First aid in the workplace
- Managing the risk of falls at workplaces
- Hazardous manual tasks
- Managing the risk of falls in housing construction
- Managing electrical risks in the workplace
- Demolition work
- Excavation work
- Work health and safety consultation, cooperation and coordination
- Managing the work environment and facilities
- How to manage work health and safety risks
- Managing risks of plant in the workplace
- Construction work

**Tasmania**

Work Health and Safety Act 2012  
 Work Health and Safety (Transitional and Consequential Provisions) Act 2012  
 Work Health and Safety Regulations 2012  
 Work Health and Safety (Transitional) Regulations 2012  
 Legislation for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations>  
 Codes of Practice for TAS: <https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice>

Details of permits, licenses or access required by regulatory bodies (add or delete as required):

- Permits from local council
- Authorisation to commence work
- Any required documents.



**SIGNATORIES OF THE SAFE WORK METHOD STATEMENT**

The signed and dated personnel listed below have cooperated in the consultation and development of this Safe Work Method Statement which has been approved by the Person/s Conducting a Business or Undertaking (PCBU). In signing this Safe Work Method Statement each individual acknowledges and confirms that they have read this SWMS in full, having raised any questions for items on this Safe Work Method Statement that require clarification, and confirms that they are competent, skilled and knowledgeable for the task assigned to them. Every person acknowledges that they have received the relevant training and qualifications where required, before carrying out any work contained in this Safe Work Method Statement. By signing this Safe Work Method Statement each individual agrees to work safely, to follow any safe work instructions which are provided, and agrees to use all Personal Protective Equipment where appropriate.

Worker Name	Position	Signature	Date	Time	Supervisor
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		

**SAFE WORK METHOD STATEMENT MONITORING AND REVIEW**

**The SWMS must be reviewed regularly** to make sure it remains effective and must be reviewed (and revised if necessary) if relevant control measures are needed. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When the SWMS has been revised the PCBU must ensure that all persons involved with the work are advised that a revision has been made and how they can access the revised SWMS, including all persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS. All workers that will be involved in the work must be provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

**The SWMS must be monitored regularly** for the effectiveness of ensuring hazard controls are effective in reducing the risk of incidents, keeping the workplace safe for all personnel. The person responsible for monitoring the effectiveness of the Safe Work Method Statement should employ a multi-faceted approach which includes but is not limited to:

1. Spot Checks.
2. Consultation with workers, contractors and sub-contractors.
3. Internal audits on a continual basis.

An approach of continuous improvement, promptly recording inconsistencies or deficiencies, followed up by immediate corrective action and consultation with all relevant personnel ensures that the PCBU is consistently developing ever-improving systems of safe work principles.

REVIEW NUMBER	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7
NAME							
INITIALS							
DATE							

SAFE WORK METHOD STATEMENT REVIEW CHECKLIST			
This Safe Work Method Statement Review Checklist is to be followed and used upon initial development of the SWMS to help ensure that all steps have been adequately taken before work commences. Think of this document as an internal audit review checklist before commencing work, and may form part of a Toolbox Talk (safety meeting) and may be used as an opportunity for education and training.			
ITEMS WHICH MUST BE INCLUDED IN THE SWMS	COMPLETED	TO BE DONE	COMMENTS
The company details have been entered, including the project name and address.	<input type="checkbox"/>	<input type="checkbox"/>	
Names and signatures of all relevant personnel consulted during the development of the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Name, signature, position and date signed of the person approving the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Specific personnel and qualifications, experience is noted in the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Provides a step-by-step process of tasks required to carry out the activity or task.	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate risk assessment of any identified hazards has been completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Foreseeable hazards are identified and documented for each step.	<input type="checkbox"/>	<input type="checkbox"/>	
Any hazards listed in any site risk assessments have been added to the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS initial risk (IR) column as well as residual risk (RR) columns completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Check control measures added to the SWMS are the most effective solutions.	<input type="checkbox"/>	<input type="checkbox"/>	
Responsible person is assigned and listed on the SWMS for the implementation of control measures.	<input type="checkbox"/>	<input type="checkbox"/>	
Permit requirements specified, such as Hot Work, Electrical Work, Work at Heights etc.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS identifies plant and equipment to be used.	<input type="checkbox"/>	<input type="checkbox"/>	
Details of inspection checks required for any equipment listed are noted on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Describes any mandatory qualifications, experience, training, skills required to perform the work.	<input type="checkbox"/>	<input type="checkbox"/>	
Applicable personal protective equipment is selected on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Lists any required permits or licenses.	<input type="checkbox"/>	<input type="checkbox"/>	
Reflects and documents any legislative references and/or Australian Standards.	<input type="checkbox"/>	<input type="checkbox"/>	
Identifies any hazardous substances used with specific control measures in line with any SDS.	<input type="checkbox"/>	<input type="checkbox"/>	
<b>REVIEWED BY</b>		<b>DATE REVIEWED</b>	
<b>SIGNATURE</b>		<b>DATE COMPLETED</b>	